

BUILDING D

Unit	Age & Brand	Tonnage	Temp. Difference	Heat pump or Straight cool & ton	Pressures	Amp Draw	Comments						
301	2022 Rheem	3 ton	71 in, 54 out	SC	2.5 ton	103/197	6	Good Condition					
302	1996 ICP	2 ton	66 in, 45 out	SC	2 ton	55/133 R-22	5.7	Poor Condition	Strongly suggest changing this system. Not it good condition to move to stands				
303	2022 Trane	2 ton	68 in, 47 out	SC	2 ton Run-Tru	108/188	4.9	Good Condition					
304	2012 ICP	2.5 ton	63 in, 43 out	SC	2.5 ton	90/206	6.1	Poor Condition	Filter drier very rusted out				
305	2022 Rheem	2 ton	64 in, 45 out	SC	2 ton	95/191	5.3	Good Condition					
306	2010 Amana	3 ton	66 in, 49 out	SC	3 ton	78/189	7.6	Poor Condition					
206	2017 Trane	2 ton	76 in, 60 out	SC	2 ton Ameristar	81/283	5.1	Fair Condition					
205	2021 Carrier	2 ton	69 in, 52 out	SC	2 ton	71/180	4.9	Good Condition					
204	2009 Trane	2 ton	68 in, 51 out	SC	2 ton	81/182	5.4	Poor Condition					
203	2010 Trane	2 ton	65 in, 49 out	SC	2 ton	97/202	\$7.00	Poor Condition	14 years old compressor struggling to kick in. If trying to save unit Add a hard start kit				
202	2023 Aspen	2 ton	69 in, 48 out	SC	2 ton York	104/191	5.1	Good Condition					
201	2016 Rheem	2.5 ton	74 in, 47 out	SC	2.5 ton	106/220	6.3	Fair/Poor condition					
101	2021 Carrier	2 ton	68 in, 52 out	SC	2 ton	100/230	5.7	Good Condition					
102	2017 Rheem	2 ton	70 in, 56 out	SC	2 ton	84/193	4.8	Fair/Poor condition					
103	2020 York	2 ton	71 in, 52 out	SC	2 ton	85/187	5.1	Good/Fair condition					
104	2022 Aspen	2 ton	70 in, 45 out	SC	2 ton York	107/199	5.2	Good Condition					
105	2018 ADP	2 ton	73 in, 54 out	SC	2 ton York	76/184	5.5	Fair Condition					
106	2014 Carrier	2 ton	70 in, 50 out	SC	2 ton	105/215	5.6	Good Condition					