

BUILDING K

Unit	Age & Brand	Tonnage	Temp. Difference	Heat Pump or Straight cool & tonb	Pressures	Amp draw	Comments			
301	2004 Carrier	2.5 ton	65 in 46 out	SC	2 ton 2002	50/143 R-22	4.9	Poor Condition	R-22 Refrigerant strongly suggest changing system	
302	2019 lcp	2.5 ton	63 in, 48 out	SC	2.5 ton	99/206	5.9	Fair Condition		
303	2024 Carrier	3 ton	67 in,47 out	HP	2.5 ton	108/207	5.4	Good Condition		
304	2018 Goodman	3 ton	67 in, 50 out	SC	2.5 ton	113/196	5.9	Fair Condition		
305	2021 Carrier	3 ton	68 in, 48 out	SC	2.5 ton Bryant	106/197	5.8	Good Condition		
306	2018 Carrier	3 ton	67 in, 48 out	SC	3 ton Bryant	108/219	6.2	Fair Condition		
206	2012 Trane	3 ton	69 in, 56 out	SC	3 ton	69/188	7.4	Poor Condition	Unit low on refrigerant need to get checked	
205	2011 Rheem	2 ton	71 in, 51 out	SC	2.5 ton	98/215	5.8	Poor Condition		
204	2016 Daikin	2 ton	68 in, 55 out	SC	2 ton	74/208	5.6	Poor Condition	Unit low on refrigerant not cooling properly	
203	2023 Rheem	2 ton	67in, 50 out	SC	2 ton	118/201	5	Good Condition		
202	2017 Goodman	2 ton		SC	2 ton			Fair Condition	Couldnt turn on no power to thermostat	
201	2022 Trane	2.5 ton	70 in, 60 out	SC	2.5 ton	52/182	5.9	Good Condition	unit low on refrigerant not cooling properly	
101	2007 Carrier	2 ton	67 in, 50 out	SC	2 ton	50/121 R-22	5.6	Poor Condition	R-22 Refrigerant strongly suggest changing system	
102	2021 Lennox	2 ton	71 in, 52 out	SC	2 ton	118/202	5.5	Fair Condition		
103	2014 Rheem	3 ton	73 in, 68 out	SC	2.5 ton	60/179	6	Poor Condition	unit low on refrigerant not cooling properly	
104	2011 Rheem	2 ton	73 in, 52 out	SC	2 ton	121/215	5.6	Poor Condition		
105	2014 Carrier	2 ton	74 in, 53 out	SC	2 ton	108/218	5.7	Poor Condition		
106	2021 Trane	2.5 ton	71 in, 51 out	SC	2.5 ton	95/225	7.1	Good Condition		